

Aberdeen Fire Rescue Department



Serving the community since 1921

910-944-7888

800 HOLLY STREET
ABERDEEN, NC 28315

Fax: 910-944-9755



Fire Alarm Systems

Building: _____

Address: _____

Inspector: _____ Date: _____

Date of Last Inspection: _____ Outstanding Violations: Yes No

General

Were building alterations/renovations made since last inspection? Yes No

Has a new alarm been added since last inspection? Yes No

Were new detectors or alarms added since last inspection? Yes No

Control Panel

Is green power light on? Yes No

Are any trouble lights on? Yes No

If yes, why? _____

Are supervisory lights on? Yes No

If yes, why? _____

Does panel appear in good condition? Yes No

Batteries

Are batteries in good condition without signs of corrosion? Yes No

Fire Alarm Boxes (Manual Stations)

Are fire alarm boxes clear, unobstructed, and identified? Yes No N/A

Fire Alarm Notification Appliances

Do number and location of fire alarm notification appliances appear adequate? Yes No N/A

Quarterly Tests Recorded

Test of fuses? Yes No N/A

Test of interfaced equipment? Yes No N/A

Test of panel lamps or LED's? Yes No N/A

Test of supervisory signal devices (except tamper switches)? Yes No N/A

Test of off-premises transmission equipment? Yes No N/A

Semiannual Tests Recorded

Lead acid battery discharge test? Yes No N/A

Lead acid battery load test? Yes No N/A

Lead acid battery specific gravity test? Yes No N/A

